

# Cannon Air Force Base

## 2020 Drinking Water Quality Report



### INSIDE THIS REPORT

[Where Does Your Drinking Water Come From](#)

[Testing Your Drinking Water](#)

[Sources of Contamination to Drinking Water](#)

[Who Needs to Take Special Precautions](#)

[Educational Information: Lead, Fluoride, Arsenic, PFOA/PFOS](#)

[Who to Contact](#)

[2020 Sampling Results](#)

[Definitions and Abbreviations](#)

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. In 2020, we conducted tests for various contaminants and these results can be found on page 4 of this report. Additionally, we have conducted Air Force-mandated sampling for PFOA/PFOS in 2020 and the results are located on page 3.

Bioenvironmental Engineering Flight  
27 Special Ops Medical Readiness Sq

An important part of our day-to-day operations is to provide high-quality, safe, reliable drinking water to our 27 SOW Air Commandos, their families, and our guests. In 2020, the water that Cannon AFB provided met or surpassed all federal and state primary drinking water regulations. We take pride in ensuring that we take care of you and your water supply. This report summarizes the results of our base engineers in Civil and Bioenvironmental Engineering, and is our way of showing you the results of these efforts.

GRAHAM.JONATHAN.  
W.1134798684

Digitally signed by  
GRAHAM.JONATHAN.W.1134798684  
Date: 2021.06.29 11:11:21 -06'00'

JONATHAN W. GRAHAM, Colonel, USAF  
Vice Commander

### Where does your drinking water come from?

Cannon AFB uses groundwater as the source for all potable water supplied to the base and Chavez housing areas. Water is extracted from the Ogallala Aquifer using three wells located on the base property. This water is disinfected with chlorine and delivered to the consumer through a network of underground pipes known as a distribution system. Based on the size of our system and the number of customers, the base wells are registered with the New Mexico Environment Department (NMED) as community water sources.

### Testing your drinking water

The US Environmental Protection Agency (EPA) and NMED require the AF to monitor for certain contaminants in the drinking water. The table on page 4 lists all of the drinking water contaminants that were detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in our water. Testing for these contaminants is done less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Removing all contaminants in most cases, would not provide increased protection of public health. Unless otherwise noted, the data presented in the table on page 4 is from testing done in the calendar year of this report. On page 5, definitions and abbreviations are provided to better understand these terms.

### NMED Notice of Violation (NOV) \*Please see attachment.

Cannon AFB is required to collect one Total Trihalomethane (TTHM) every compliance period. For the 2020 (July-September) compliance period, the sample was taken; however, the sample did not arrive at the lab at the correct temperature causing the sample to be invalidated. The sample was unable to be recollected within the compliance period. Although this incident was not an emergency, as our customers, you have a right to know what happened. Cannon AFB will return to compliance by July 2021 when the sample is collected and analyzed.

### Sources of contamination to drinking water

Drinking water can reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. At low levels, these substances are generally not harmful in drinking water. Contaminants that may be present in source water include:

- (A) **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife
- (B) **Inorganic contaminants**, such as salts and metals,

which can be naturally occurring or results from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses

- (C) **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff
- (D) **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production or mining activities

In order to ensure that your tap water is safe to drink, the US EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### Who needs to take special precautions

Some people may be more vulnerable to contaminants in drinking water than others. Immuno-compromised persons such as individuals with cancer undergoing chemotherapy, organ transplant recipients, people with HIV/AIDS, other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers, or contact the EPA, or Centers for Disease Control (CDC) on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants. More information is available from the Safe Water Drinking Hotline (800-426-4791).

### Educational Information:

#### Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cannon AFB Water System is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have it tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

## Fluoride

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth called dental fluorosis. Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of permanent teeth. This problem occurs only in developing teeth before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use of fluoride-containing products by young children. Older children and adults may safely drink the water. The drinking water provided by the Cannon AFB Water System had the following concentrations of fluoride:

| Sample Location | Sample Date | Result (mg/L) |
|-----------------|-------------|---------------|
| Water Plant     | 11/30/2020  | 1.97          |

The AF is required to notify you when the fluoride levels in your drinking water exceed 2 mg/L because of the above described cosmetic dental problems. Drinking water containing more than 4 mg/L of fluoride (EPA's drinking water standard) can increase your risk of developing bone disease. Cannon AFB drinking water does not contain more than 4 mg/L of fluoride. Cannon AFB continues to monitor fluoride levels and will inform you if the fluoride concentration exceeds 4 mg/L. Fluoride contamination is rarely due to human activity. It occurs naturally in some areas and is found in high concentrations in our source water.

Some home water treatment units can remove fluoride from drinking water. To learn more about available home water treatment units, contact the National Science Foundation (NSF) International at 1-720-227-0640.

Additionally, Cannon AFB provides no-cost low-fluoride water (0.7 to 1.2 mg/L) at the CDCs and at the following self-service locations:

- The Water Plant (Bldg. 336)
- Doc Stewart Community Center (Bldg. 9982)
- Airman's Attic (Bldg. 76)
- The Shoppette on the SE side of base (Bldg. 4623)

To reduce fluoride intake, use water from these locations to drink and where water is integral to food preparation.

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in dorms, schools, occupational shops, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.**

## Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## Perfluorooctanoic acid (PFOA)/ Perfluorooctane sulfonates (PFOS)

These fluorinated organic chemicals are a part of a larger group of chemicals referred to as Perfluoroalkyl and Polyfluoroalkyl substances (PFAS). Although some types of PFAS are no longer used, some products may still contain them: food packaging materials, nonstick cookware, stain resistant carpet treatments, water-resistant clothing, cleaning products, paints, varnishes and sealants, some cosmetics, and firefighting foam at air-fields.

Should your drinking water contain PFOA/PFOS above the EPA Lifetime Health Advisory of 70 ppt, you would be instructed to use an alternative or treated water source for any activity in which you might swallow water i.e., drinking, food preparation, cooking, brushing teeth, and preparing infant formula. Cannon AFB sampled for PFOA/ PFOS in the drinking water on 12 November 2020. Cannon AFB Water System had the following concentrations of PFOS/PFOA:

| Sample Location | Sample Date | Results* (PPT) |      | EPA Health Advisory Limit (PPT) |
|-----------------|-------------|----------------|------|---------------------------------|
|                 |             | PFOS           | PFOA |                                 |
| Well 5          | 11/30/2020  | 0.27           | 0.67 | 70                              |
| Entry Point 1   | 11/30/2020  | 0.44           | 0.69 | 70                              |
| Well 9          | 11/30/2020  | 0.36           | 0.72 | 70                              |

\*All sample results were well below EPA limits and no action is required on your part. Updated EPA sampling methods now detect PFOS/PFOA at much lower levels than previously possible in an effort to protect your health. Cannon AFB will continue to regularly sample for PFOS/PFOA as long as it is detectable in your water.

## Who to Contact

- For water system questions, contact Civil Engineer Squadron Customer Service at 575-784-2001.
- For water quality questions, contact Bioenvironmental Engineering Flight at 575-784-4063.
- For Fluoride and dental health questions, contact the Dental Clinic at 575-904-4142.
- CDC/ATSDR: CDC Info: <https://www.cdc.gov/cdc-info/>, or (800) 232-4636 for PFAS information.

# 2020 Sampling Results

| Contaminants   | MCLG or MRDLG | MCL, TT, or MRDL | Detect In Your Water | Low Range | High Range | Sample Date | Violation | Typical Source  |
|--|---------------|------------------|----------------------|-----------|------------|-------------|-----------|---|
| <b>Disinfectants &amp; Disinfection By-Products</b>                                      |               |                  |                      |           |            |             |           |   |
| Haloacetic Acids (ppb)   | NA            | 60               | ND                   | NA        | NA         | 2020        | No        | By-product of drinking water chlorination   |
| Total Trihalomethanes (ppb)  | NA            | 80               | 25.3                 | NA        | NA         | 2020        | No        | By-product of drinking water disinfection   |
| Chlorine (mg/L)  | 4             | 4                | 0.20*                | 0.03      | 0.70       | 2020        | No        | Water additive used to control microbes<br><br>*Compliance based on annual average  |
| <b>Inorganic Contaminants [ * denotes contaminants are sampled on a 3 Year Cycle ]</b>   |               |                  |                      |           |            |             |           |   |
| Arsenic (ppb)  | 0             | 10               | 4.1                  | 3         | 4.1        | 2017 *      | No        | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes                    |
| Barium (ppm)   | 2             | 2                | .03                  | .027      | .03        | 2017 *      | No        | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits                                |
| Chromium (ppb)   | 100           | 100              | 1.2                  | 1.2       | 1.2        | 2017 *      | No        | Discharge from steel and pulp mills; Erosion of natural deposits  |
| Fluoride (ppm)   | 4             | 4                | 1.97                 | 1.97      | 1.97       | 2020        | No        | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Nitrate (ppm)  | 10            | 10               | 3.8                  | 1.6       | 3.8        | 2020        | No        | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits                               |
| Selenium (ppb)   | 50            | 50               | 8.2                  | 6.4       | 8.2        | 2017 *      | No        | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines                          |
| Lead - Action Level at Consumer Taps (ppb)   | 0             | AL=15            | ND                   | NA        | NA         | 2019 *      | No        | Corrosion of household plumbing systems; Erosion of natural deposits  |
| Copper - Action Level at Consumer Taps (ppm)   | 1.3           | AL=1.3           | 0.208                | NA        | NA         | 2019 *      | No        | Corrosion of household plumbing systems; Erosion of natural deposits  |
| <b>Microbiological Contaminants</b>  |               |                  |                      |           |            |             |           |   |
| Fecal coliform/E. coli   | NA            | TT               | Absent               | NA        | NA         | 2020        | No        | Human and animal fecal waste  |
| <b>Radioactive Contaminants [ * denotes contaminants are sampled on a 6 Year Cycle ]</b> |               |                  |                      |           |            |             |           |   |
| Alpha emitters (pCi/L)   | 0             | 15               | 9                    | 0         | 9          | 2018 *      | No        | Erosion of natural deposits   |
| Uranium (ug/L)   | 0             | 30               | 6                    | 4.7       | 6          | 2018 *      | No        | Erosion of natural deposits   |

## Contaminants listed below were monitored for, but not detected in your water

|                        |                          |                    |                            |
|------------------------|--------------------------|--------------------|----------------------------|
| 1,1,1-Trichloroethane  | Benzene                  | Ethylbenzene       | Simazine                   |
| 1,1,2-Trichloroethane  | BHC-Gamma                | Endrin             | Styrene                    |
| 1,1-Dichloroethylene   | Carbon Tetrachloride     | Heptachlor         | Tetrachloroethylene        |
| 1,2,4-Trichlorobenzene | Chlorobenzene            | Heptachlor Epoxide | Toluene                    |
| 1,2-Dichloroethane     | Chlordane                | Methoxychlor       | Toxaphene                  |
| 1,2-Dichloropropane    | CIS-1,2-Dichloroethylene | O-Dichlorobenzene  | Trans-1,2-dichloroethylene |
| 2,4,5-TP (Silvex)      | Dalapon                  | P-Dichlorobenzene  | Trichloroethylene          |
| 2,4-D                  | Dichloromethane          | Pentachlorophenol  | Vinyl Chloride             |
| Atrazine               | Dinoseb                  | Picloram           | Xylenes, Total             |

### Definitions and Abbreviations

| Term                     | Definition   | Term                   | Definition  |
|--------------------------|--|------------------------|---|
| 3-Year Compliance Period | Each compliance cycle has three 3-year compliance periods. For example; Cannon AFB's compliance period for heavy metals started with the first compliance period running from 1 Jan 2017 to 31 Dec 2019, the second period runs from 1 Jan 2020 to 31 Dec 2022, and the third from 1 Jan 2023 to 31 Dec 2025. Water systems must collect the assigned samples at anytime within the compliance period. | MCLG                   | Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety   |
| ppm                      | parts per million, or milligrams per liter (mg/L)  | MCL                    | Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology   |
| ppb                      | parts per billion, or micrograms per liter (µg/L)  | TT                     | Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water   |
| ppt                      | parts per trillion, or nanograms per liter   | AL                     | Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow  |
| pCi/L                    | picocuries per liter (a measure of radioactivity)  | Variances & Exemptions | State or EPA permission not to meet an MCL or a treatment technique under certain conditions  |
| % positive samples/month | Percent of samples taken monthly that were positive  | MRDLG                  | Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants |
| NA                       | Not Applicable   | MRDL                   | Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants                             |
| ND                       | Not Detected   | MNR                    | Monitored Not Regulated   |
| NR                       | Monitoring not required, but recommended   | MPL                    | State Assigned Maximum Permissible Level  |

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring Requirements Not Met for Cannon Air Force Base Water System

***Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.***

Our water system violated drinking water requirements over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we are doing (did) to correct these situations.

*\*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2020 (July – September) we did not complete all monitoring or testing for disinfection byproducts (Total Trihalomethanes and Haloacetic Acids) and therefore cannot be sure of the quality of your drinking water during that time. \**

**Table 1**

| Contaminants         | Sample Name (Address)      | Sampling Frequency        | Compliance Period |
|----------------------|----------------------------|---------------------------|-------------------|
| Total Trihalomethane | TTHM-IND Radar Maintenance | Yearly (July – September) | 2020              |

#### **What should you do?**

There is nothing you need to do. You do not need to boil your water or take other corrective actions. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

#### **What happened and what is being done?**

Cannon AFB is required to collect one Total Trihalomethane (TTHM) every compliance period. For the 2020 (July-September) compliance period, the sample was taken; however, the sample did not arrive at the lab at the correct temperature causing the sample to be invalidated. The sample was unable to be recollected within the compliance period. We anticipate resolving the problem by July 2021.

#### **For more information, please contact:**

Emily Warrenfeltz, SSgt at 575-784-4063 or at:

Cannon Air Force Base Water System, NM3567905  
224 West D.L. Ingram Ave  
Cannon, NM 88103

***\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. \****